

SRI LANKA STANDARD 1150 Part 1 : 2009
IEC 61347-2-8 : 2006

**SPECIFICATION FOR BALLASTS
FOR TUBULAR FLUORESCENT LAMPS
PART 1: GENERAL AND SAFETY REQUIREMENTS**
(First Revision)

SRI LANKA STANDARDS INSTITUTION

Sri Lanka Standard
SPECIFICATION FOR BALLASTS FOR TUBULAR FLUORESCENT LAMPS
PART 1: GENERAL AND SAFETY REQUIREMENTS
(First Revision)

SLS 1150 Part 1 : 2009
IEC 61347-2-8 : 2006

Gr. L

Copyright Reserved
SRI LANKA STANDARDS INSTITUTION
Victoria Place, No. 17,
Elvitigala Mawatha,
Colombo - 08.
Sri Lanka

Sri Lanka Standard
SPECIFICATION FOR BALLASTS FOR TUBULAR FLUORESCENT LAMPS
PART 1 : GENERAL AND SAFETY REQUIREMENTS
(First Revision)

NATIONAL FOREWORD

This standard was approved by the Sectoral Committee on Electrical Appliances and Accessories and was authorized for adoption and publication as a Sri Lanka Standard by the Council of Sri Lanka Standards Institution on 2009-10-28.

This is the first revision of the of **SLS 1150 Part 1 : 1997** and identical with **IEC 61347-2-8: 2006** Lamp controlgear, Part 2-8 : Particular requirements for ballasts for fluorescent lamps, Edition 1.1 2006-03, published by the International Electrotechnical Commission (IEC).

Terminology and conventions

The text of the International Standard has been accepted as suitable for publication, without deviation, as a Sri Lanka Standard. However, certain terminology and conventions are not identical with those used in Sri Lanka Standards; attention is therefore drawn to the following:

- a) Wherever the words “International Standard” appear referring to this standard they should be interpreted as “Sri Lanka Standard”.
- b) Wherever the page numbers are quoted they are the page numbers of IEC standard.
- c) The comma has been used as a decimal marker. In Sri Lanka Standards it is the current practices to use a full point on the base line as a decimal marker.

CROSS REFERENCES

International Standards	Corresponding Sri Lanka Standards
IEC 61347-1: Lamp controlgear – Part 1 : General and safety requirements	SLS IEC 61347-1: Lamp controlgear – Part 1 : General and safety requirements

**NORME
INTERNATIONALE
INTERNATIONAL
STANDARD**

**CEI
IEC**

61347-2-8

Edition 1.1

2006-03

Edition 1:2000 consolidée par l'amendement 1:2006
Edition 1:2000 consolidated with amendment 1:2006

Appareillages de lampes –

**Partie 2-8:
Prescriptions particulières pour les ballasts
pour lampes fluorescentes**

Lamp controlgear –

**Part 2-8:
Particular requirements for ballasts
for fluorescent lamps**



Numéro de référence
Reference number
CEI/IEC 61347-2-8:2000+A1:2006

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	9
1 Scope.....	11
2 Normative references.....	11
3 Definitions.....	11
4 General requirements.....	13
4.1 Capacitors and other components.....	13
4.2 Thermally protected ballasts.....	13
5 General notes on tests.....	13
6 Classification.....	13
7 Marking.....	13
7.1 Mandatory markings.....	13
7.2 Information to be provided, if applicable.....	15
7.3 Other information.....	15
8 Protection against accidental contact with live parts.....	15
9 Terminals.....	15
10 Provisions for earthing.....	15
11 Moisture resistance and insulation.....	15
12 Electric strength.....	15
13 Thermal endurance test for windings.....	15
14 Ballast heating.....	17
14.1 Pre-test, checks and measures.....	17
14.2 Voltage across capacitors.....	17
14.3 Ballast heating test.....	17
15 High-voltage impulse testing.....	21
16 Fault conditions.....	23
17 Construction.....	23
18 Creepage distances and clearances.....	25
19 Screws, current-carrying parts and connections.....	25
20 Resistance to heat, fire and tracking.....	25
21 Resistance to corrosion.....	25
22 No-load output voltage.....	25
Annexes.....	27
Figure I.1 – Test circuit for ballasts, for lamps with internal starting devices.....	33
Figure J.1 – Test hood for ballast heating test.....	39
Figure J.2 – Test corner for ballast heating.....	39
Table 1 – Abnormal conditions – Capacitor test voltages.....	17
Table 2 – Maximum temperatures.....	19
Table 3 – Limiting temperatures of windings under abnormal operating conditions and at 110 % of rated voltage for ballasts subjected to an endurance test duration of 30 days.....	21