

SRI LANKA STANDARD 9 : PART 2 : 2001
UDC 691.328.5 : 692.4

SPECIFICATION FOR
ASBESTOS-CEMENT PRODUCTS
PART 2 : CORRUGATED SHEETS
(SECOND REVISION)

SRI LANKA STANDARDS INSTITUTION

**SPECIFICATION FOR ASBESTOS-CEMENT PRODUCTS
PART 2 : CORRUGATED SHEETS
(SECOND REVISION)**

SLS 9 : Part 2 : 2001

Gr. 11

**SRI LANKA STANDARDS INSTITUTION
No. 17, Victoria Place
Elvitigala Mawatha
Colombo 08
SRI LANK**

SRI LANKA STANDARD
SPECIFICATION FOR ASBESTOS-CEMENT PRODUCTS
PART 2 : CORRUGATED SHEETS
(SECOND REVISION)

FOREWORD

This standard was approved by the Sectoral Committee on Building and Construction Materials and was authorized for adoption and publication as a Sri Lanka Standard by the Council of the Sri Lanka Standards Institution on 2001- 11-22.

This part of the standard specifies corrugated sheets, Part 1 of this standard specifies the flat sheet.

This Standard was first published in 1969 and subsequently revised in 1988. This is the second revision. This revision includes the following:

- a) Amosite (brown asbestos) is not permitted;
- b) Scale of sampling has been revised; and
- c) Criteria for conformity on shape, finish and geometrical characteristics.

For the purposes of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a test or an analysis shall be rounded off in accordance with **CS 102**. The number of significant figures to be retained in the rounded off value shall be the same as that of the specified value in this standard.

In the preparation of this standard, the assistance derived from the publications of the International Organization for Standardization, the British Standards Institution and the Bureau of Indian Standard are gratefully acknowledged.

1 SCOPE

This part of the standard specifies the requirements, methods of sampling and test for straight asbestos-cement corrugated sheets to be used mainly for roofing and cladding.