

SRI LANKA STANDARD 734 : PART 4 : 2017
UDC 621.316

**SPECIFICATION FOR
13 A PLUGS, SOCKET-OUTLETS,
ADAPTORS AND CONNECTION UNITS
PART 4 : SPECIFICATION FOR 13A FUSED
CONNECTION UNITS SWITCHED AND
UNSWITCHED**

SRI LANKA STANDARDS INSTITUTION

Sri Lanka Standard
SPECIFICATION FOR 13 A PLUGS, SOCKET-OUTLETS,
ADAPTORS AND CONNECTION UNITS
PART 4: SPECIFICATION FOR 13A FUSED CONNECTION UNITS
SWITCHED AND UNSWITCHED

SLS 734: Part 4: 2017
(AMD 521 Attached)

Gr.19

Copyright Reserved
SRI LANKA STANDARDS INSTITUTION
17, Victoria Place
Elvitigala Mawatha
Colombo – 08
Sri Lanka

CONTENTS

CLAUSE	PAGE
0 Foreword.....	3
1 Scope.....	4
2 References.....	4
3 Terms and definitions.....	6
4 Conditions of use.....	8
5 General conditions for type testing.....	9
6 Classifications.....	10
7 Marking and labelling.....	11
8 Clearances, creepage distances and solid insulation.....	12
9 Accessibility of live parts.....	17
10 Provision for earthing.....	17
11 Terminals.....	18
12 Construction of connection units.....	23
13 Resistance to ageing, resistance to humidity and protection provided by enclosures.....	27
14 Insulation resistance and electric strength.....	31
15 Temperature rise.....	33
16 Breaking capacity of connection units.....	35
17 Normal operation of connection units.....	36
18 Connection of flexible cables and cable anchorage.....	36
19 Mechanical strength.....	38
20 Screws, current-carrying parts and connections.....	40
21 Resistance to heat.....	41
22 Resistance to abnormal heat and fire.....	42
23 Resistance to excessive residual stresses and to rusting.....	43

Tables

TABLE 1 Schedule of tests.....	9
TABLE 2 Minimum clearances for basic insulation.....	14
TABLE 3 Minimum creepage distances (mm) for basic insulation.....	16
TABLE 4 Withstand voltages for insulation types.....	17
TABLE 5 Torque values for screws and nuts.....	18
TABLE 6 Actuator test force.....	26
TABLE 7 Tightening torque values for cable gland.....	29
TABLE 8 Test voltage across the open contacts for verifying the suitability for isolation, referred to the rated voltage and to the altitude where the test is carried out.....	33
TABLE 9 Permitted temperature rises.....	34
TABLE 10 Cable grip tests related to size of flexible cable.....	37
TABLE D.1 Rated impulse withstand voltage for connection units energized directly from the low-voltage mains.....	57
TABLE F.1 Test voltages for verifying clearances at sea level.....	59

Figures

FIGURE 1 Solid link for test on fuse clips.....	44
FIGURE 2 Pendulum impact test : General view of apparatus.....	45
FIGURE 3 Pendulum impact test: Constructional details of striking elements.....	46
FIGURE 4 Pendulum impact test: Constructional details of mounting support for test samples.....	47
FIGURE 5 Calibrated link.....	48
FIGURE 6 Calibration jig for calibrated link.....	49

Annexes

ANNEX A	The Construction and calibration of a calibrated Link.....	51
ANNEX B	Measurement of clearances and creepage distances.....	52
ANNEX C	Determination of the comparative tracking index (CTI) and proof tracking index (PTI)	56
ANNEX D	Relation between rated impulse withstand voltage, rated voltage and overvoltage category	57
ANNEX E	Pollution degree	57
ANNEX F	Impulse voltage test	58

Sri Lanka Standard
SPECIFICATION FOR 13 A PLUGS, SOCKET-OUTLETS,
ADAPTORS AND CONNECTION UNITS
PART 4 SPECIFICATION FOR 13A FUSED CONNECTION UNITS
SWITCHED AND UNSWITCHED

FOREWORD

This Standard was approved by the Sectoral committee on Electrical appliances and accessories and was authorized for adoption and publication as a Sri Lankan standard by the council of the Sri Lanka standards institution on 2017-06-14.

This standard is presented in five parts as given below and Part 1 and Part 2 are second revision of **SLS 734: 1996** and other parts are newly included in this standard:

- Part 1: Specification for rewirable and non-rewirable 13A fused plugs
- Part 2: Specification for 13A switched and unswitched socket outlets
- Part 3: Specification for adaptors
- Part 4: Specification for 13A fused connection units, switched and unswitched
- Part 5: Specification fused conversion plugs

This is Part 4 of the **SLS 734** and it specifies requirements for 13 A fused fixed connection units for household, commercial and light industrial purposes, with particular reference to safety in normal use.

All values given in this specification are in SI unit.

For the purpose of deciding whether a particular requirement of this standard is complied with the final value observed or calculated, expressing the results of a test or an analysis shall be rounded off in accordance with **SLS 102**. The number of figures to be retained in the rounded off values shall be the same as that of the specified value in this standard.

In the preparation of this standard, the assistance derived from the **BS 1363** for 13 A Plugs, Socket outlets, Adaptors and Connection units, Part 4: 2016 Specification for 13A Fused connection units switched and unswitched, is gratefully acknowledged.